


ENGINEERING PRINCIPLES OF MICROBIOLOGICALLY INDUCED CORROSION



Course Overview

Course Description

This course introduces microbially induced corrosion (MIC), its underlying mechanisms, and the engineering strategies used to detect, mitigate, and manage it.

MIC is a broad category of biologically driven degradation, and its consequences appear across nearly every infrastructure sector engineers work in. These include water distribution and wastewater systems, oil and gas pipelines, marine structures, and industrial processing facilities. The course builds from electrochemical and microbiological fundamentals through to practical engineering application. It emphasizes inspection and monitoring technologies, protective systems and lifecycle risk assessment.

Learning Objectives

Upon successful completion of this course, participants will be able to:

- Understand the electrochemical principles governing metallic corrosion and how microbial activity modifies those processes
- Learn the principal microorganism groups associated with MIC and describing the metabolic mechanisms by which each contributes to material degradation
- Understand the MIC vulnerability of water distribution systems, wastewater infrastructure, pipelines, marine structures, and industrial facilities
- Know the appropriate inspection and monitoring technologies for MIC detection in specific infrastructure contexts
- Understand the relative effectiveness of protective coatings, cathodic protection, biocide treatment, and operational mitigation strategies for controlling MIC
- Learn how to apply lifecycle engineering principles to MIC risk assessment and asset management planning

Intended Audience

This course is suitable for civil, mechanical, environmental, chemical, materials, marine, and petroleum engineers.

Table of Contents

Introduction to Corrosion Engineering and Microbially Induced Corrosion.....	6
1.1 The Scope of Corrosion in Engineering Practice.....	6
1.2 What Is Microbially Induced Corrosion.....	7
1.3 Historical Recognition of MIC	8
1.4 Why MIC Matters to Modern Infrastructure	8
1.5 The Interdisciplinary Nature of MIC Engineering	9
Fundamentals of Electrochemical Corrosion	10
2.1 Corrosion as an Electrochemical Process	10
2.2 Common Forms of Corrosion	11
2.3 Passivity and Its Relevance to MIC	12
2.4 Environmental Factors Governing Corrosion Rate.....	13
2.5 How Microorganisms Interact with Electrochemical Corrosion.....	13
2.6 Corrosion Rate Measurement and Electrochemical Kinetics	14
Microbiology Fundamentals for Engineers.....	16
3.1 Why Engineers Need to Understand Microbiology.....	16
3.2 The Principal Microorganisms Associated with MIC	16
3.3 Nutrient Requirements and Environmental Conditions	18
3.4 Microbial Communities and Synergy	19
3.5 Microbial Growth Kinetics and Infrastructure Implications.....	20
Biofilm Formation and Microbial Community Dynamics	21
4.1 What Is a Biofilm	21
4.2 Stages of Biofilm Development.....	22
4.3 Electrochemical Significance of Biofilms	22
4.4 Conditions That Favor Biofilm Formation	23
4.5 Detection and Characterization of Biofilm in Engineering Systems.....	24
Microbial Corrosion Mechanisms: Sulfate-Reducing Bacteria, Acid Producers, and Anaerobic Environments	26
5.1 Sulfate-Reducing Bacteria and Anaerobic Corrosion	26

5.2 Acid-Producing Microorganisms.....	27
5.3 Anaerobic Corrosion Environments.....	28
5.4 Diagnosis of SRB and Acid-Producing Corrosion	29
5.5 Electrical MIC and Direct Electron Transfer	30
MIC in Water, Wastewater, and Building Systems.....	32
6.1 Water Distribution Systems.....	32
6.2 Wastewater Infrastructure	33
6.3 Building Mechanical Systems: HVAC and Cooling Towers	34
6.4 MIC Risk Factors in Building Plumbing Systems	35
MIC in Pipelines, Storage Tanks, and Industrial Facilities	36
7.1 Pipelines: Internal and External MIC.....	36
7.2 Storage Tanks	37
7.3 Industrial Processing Facilities	37
Marine and Offshore Microbial Corrosion	39
8.1 The Marine Microbial Environment.....	39
8.2 MIC in Offshore Structures and Pipelines.....	40
8.3 Concrete and Structural Steel in Marine Applications	40
8.4 Cathodic Protection and MIC in Marine Systems.....	41
Materials Selection, Inspection, and Monitoring.....	43
9.1 Materials Selection for MIC Resistance.....	43
9.2 Inspection Technologies for MIC Detection.....	44
9.3 Corrosion Monitoring Programs	45
9.4 Microbiological Sampling Protocols for MIC Investigation	46
Protective Systems, Chemical Treatment, and Operational Mitigation	48
10.1 Protective Coatings and Linings	48
10.2 Cathodic Protection in MIC Environments	49
10.3 Biocides and Chemical Treatment	49
10.4 Operational Mitigation Strategies	50
10.5 Integrated Mitigation Programs and Program Evaluation	51
Lifecycle Engineering, Risk Assessment, and Emerging Technologies	53

11.1 Lifecycle Engineering and MIC Risk	53
11.2 Predictive Maintenance and Digital Approaches	54
11.3 Emerging Technologies in MIC Detection and Control	54
11.4 The Engineer's Evolving Role in MIC Management	56
11.5 Economic Justification for MIC Management Investment	57
References	59

CHAPTER 1

Introduction to Corrosion Engineering and Microbially Induced Corrosion



1.1 The Scope of Corrosion in Engineering Practice

Corrosion is among the most persistent technical and economic challenges in engineering. Every metallic component placed in service begins degrading the moment it encounters its environment, and the pace of that degradation depends on the chemistry, temperature, moisture, and biological conditions surrounding it. Infrastructure owners, utilities, and industrial operators collectively spend hundreds of billions of dollars each year managing corrosion through prevention, monitoring, repair, and replacement. A landmark 2002 study sponsored by the National Association of Corrosion Engineers (NACE) International, estimated the direct cost of corrosion to the US economy at \$276 billion annually, roughly 3.1% of gross domestic product at the time (Koch et al., 2002). Indirect costs, including production downtime, safety incidents, and environmental remediation, push that figure considerably higher.

For engineers, corrosion is a design problem before it becomes a maintenance problem. Material selection, joint geometry, protective system specification, and operational procedure all influence how quickly a structure degrades. A pipeline specification that fails to account for internal water accumulation, or a storage tank designed without accessible drainage, creates the conditions for accelerated deterioration years before any visible damage appears. This course is concerned

with a particular category of corrosion that has grown in engineering significance as infrastructure ages and operating conditions change: the corrosion initiated, accelerated, or shaped by the activity of microorganisms.

1.2 What Is Microbially Induced Corrosion

Microbially Induced Corrosion (MIC) refers to corrosion processes in which microorganisms, principally bacteria and archaea, modify the local chemical environment at a metallic surface in ways that increase the rate or severity of electrochemical degradation. The term coexists in the literature with Microbiologically Influenced Corrosion (abbreviated as MIC in both cases), and both expressions describe the same phenomenon (see Figure 1).




Figure 1: A schematic of microbially induced corrosion (MIC).
Credit: Rao et al, 2023.

Microorganisms do not consume metal the way a chemical acid does. Instead, they alter conditions at the metal-fluid interface by producing acids, consuming oxygen, generating sulfides, or establishing electrochemical gradients that drive localized anodic attack. The biological and electrochemical processes are tightly coupled, which is one reason MIC has historically been difficult to separate from conventional corrosion during failure investigation.

MIC is not a single, unified mechanism. It encompasses a family of biologically driven processes involving different microorganism groups, different metabolic pathways, and different infrastructure environments. Sulfate-reducing bacteria behave very differently from sulfur-oxidizing bacteria, and the corrosion conditions they create differ accordingly. Understanding MIC will require some familiarity with the relevant microbiology, not at the level of a specialist, but sufficient to recognize which organisms are likely active in a given environment

and what engineering consequences follow from their metabolism (Little & Lee, 2007).

1.3 Historical Recognition of MIC

The connection between microorganisms and metal deterioration was suspected as early as the late nineteenth century, when investigators noticed unusual corrosion patterns in buried pipelines that could not be explained by soil chemistry alone. The critical early insight came in the 1930s when Dutch researchers Baars and Vonk demonstrated that sulfate-reducing bacteria were responsible for accelerated corrosion of iron in anaerobic soils, a finding that eventually upended conventional assumptions about which soil conditions were dangerous for buried infrastructure (Javaherdashti, 2008). For decades afterward, however, MIC remained a relatively peripheral concern in corrosion engineering, recognized in academic literature but not widely integrated into infrastructure design or maintenance practice.

The changed in scale of infrastructure failures attributable to microbial activity became undeniable. Oil and gas producers operating in the Gulf of Mexico and the North Sea in the 1970s and 1980s encountered severe internal pipeline corrosion in systems that had appeared electrochemically stable. Water utilities found their distribution networks corroding from the inside in patterns inconsistent with the bulk water chemistry. Nuclear power facilities discovered accelerated corrosion in fire protection and cooling water systems that met all established chemical specifications. In each case, investigation ultimately implicated microbial biofilms as a contributing or primary factor. By the 1990s, MIC had become a recognized engineering discipline with dedicated professional guidance from NACE International and an expanding body of research literature.

1.4 Why MIC Matters to Modern Infrastructure

Several trends have increased MIC risk across infrastructure systems in recent decades, including:

1. The sheer age of the installed asset base in North America and Europe means that pipe walls have roughened, coatings have degraded, and hydraulic dead zones have accumulated in places that engineers decades ago did not anticipate. Rough internal surfaces and stagnant zones are conditions that promote biofilm attachment and growth.
2. Water conservation policies and variable demand patterns have lowered flow velocities in distribution systems, extending water residence times

and allowing disinfectant residuals to decay before water reaches consumers. Both effects favor microbial colonization.

3. The widespread adoption of recycled and reclaimed water in industrial cooling and agricultural irrigation introduces organic nutrient loads that were absent in fresh-water systems, providing food for microbial communities that would otherwise remain sparse.

Climate also plays a role that is beginning to receive engineering attention. Warming ambient temperatures accelerate microbial metabolic rates, and in coastal regions, rising sea levels and more frequent storm surges expose infrastructure to saline water that was previously above the tidal zone. The net effect is that engineers who design, operate, or manage infrastructure today face MIC risk profiles that are significantly different from those that existed when the relevant standards and design guidance were written.

1.5 The Interdisciplinary Nature of MIC Engineering

One reason MIC investigations are challenging is that they sit at the intersection of corrosion engineering, microbiology, materials science, fluid mechanics, and chemistry. A pipeline engineer encountering an unexpected internal pit will typically approach the problem through a corrosion lens, which may be appropriate, but may miss the biological dimension entirely if microbial testing is not part of the investigation protocol. Equally, a microbiologist sampling a biofilm from a corroded surface may accurately characterize the organisms present without fully understanding the electrochemical significance of what the biofilm is doing to the metal. Effective MIC management requires these perspectives to work together.

The aim of this course is not to convert engineers into microbiologists, but to give practicing engineers enough understanding of microbial behavior to ask the right questions, recognize the warning signs, and make informed decisions about inspection, mitigation, and lifecycle planning.

CHAPTER 2

Fundamentals of Electrochemical Corrosion



Figure 2: Cross Section of Pipe with Electrochemical Corrosion.
Credit: Mi et al., 2015.

2.1 Corrosion as an Electrochemical Process

Metallic corrosion is fundamentally a process of electron transfer. A refined metal exists in a higher-energy state than the mineral compounds from which it was extracted, and thermodynamics consistently drives it toward lower-energy oxidized forms. Iron, for example, processed from hematite and magnetite at great energy cost, in the presence of water and oxygen tends to return toward iron oxides and hydroxides that is recognized as rust (see Figure 2).

Understanding this thermodynamic tendency, and the electrochemical mechanisms through which it operates, is the starting point for any serious corrosion analysis (Jones, 1996).

An electrochemical corrosion cell requires four components: an anode, a cathode, an electrolyte, and an electrical connection between the two electrode regions. At the anode, metal atoms lose electrons and dissolve into solution as ions. This oxidation process is the destructive half of the corrosion reaction because it represents actual material loss. At the cathode, electrons released at the anode are consumed by reduction reactions involving species in the surrounding environment, most commonly dissolved oxygen or hydrogen ions. The electrolyte, typically water containing dissolved salts, acids, or other ionic species, allows charge to be carried between the anodic and cathodic regions by ion movement. The corrosion reactions for iron (Fe) are illustrated in the equations below:

At the anode: $Fe \rightarrow Fe^{2+} + 2e^{-}$

At the cathode: $O_2 + 2H_2O + 4e^{-} \rightarrow 4OH^{-}$

Overall reaction: $2Fe + O_2 + 2H_2O \rightarrow 2Fe(OH)_2$

Without an intact circuit, sustained corrosion cannot occur. In practice, anodic and cathodic regions may be physically separate metals electrically connected through a structure, or they may be microscopic regions on the surface of a single piece of metal where compositional or environmental differences create localized electrochemical differences (Revie & Uhlig, 2008).

2.2 Common Forms of Corrosion

Table 1 describes the common corrosion forms and their relationship to MIC. Pitting and under-deposit corrosion are the forms most frequently associated with microbial activity.

Table 1: Common Corrosion Forms and Their Relationship to MIC.

Corrosion Form	Primary Driver	Relationship to MIC
Uniform	Bulk electrochemical exposure	Rarely the dominant MIC pattern; may coexist with localized attack
Galvanic	Dissimilar metal contact in electrolyte	Microorganisms can alter conductivity and local chemistry, intensifying galvanic interactions
Pitting	Passive film breakdown; oxygen concentration cells	Primary MIC morphology; biofilm oxygen gradients initiate and sustain pits
Crevice	Stagnant, confined electrolyte	Crevices are preferred biofilm attachment sites; MIC and crevice attack compound each other
Under-deposit	Differential aeration beneath sediment or scale	Highly susceptible; biofilms create ideal under-deposit conditions internally

Uniform corrosion distributes material loss relatively evenly across an exposed surface. It is the most predictable corrosion form because engineers can estimate material loss rates and design corrosion allowances accordingly. Atmospheric rusting of unprotected carbon steel is the archetypal example. Uniform corrosion is rarely the form associated with sudden unexpected failure because its progress is visible and can be measured.

Galvanic corrosion occurs when dissimilar metals are electrically connected in the presence of an electrolyte. The more electrochemically active metal becomes anodic and corrodes preferentially, while the more noble metal is protected. The severity of galvanic corrosion depends on the separation between the two metals in the galvanic series, the electrolyte conductivity, and the relative surface areas involved. A small anode coupled to a large cathode corrodes far more rapidly than the same small anode coupled to a comparably small cathode because the cathodic demand per unit area of anode is much higher.

Pitting corrosion is among the most dangerous localized forms because deep pits can penetrate an entire pipe wall or vessel shell while the surrounding surface remains visually intact. Pits typically initiate where protective passive films are locally disrupted or where surface defects concentrate electrochemical activity. Once a pit forms, the local chemistry inside it becomes increasingly aggressive: the interior becomes acidic and depleted of oxygen, creating a self-sustaining anodic environment that resists repassivation. MIC commonly produces pitting morphology because the oxygen gradients and localized acid generation associated with biofilms create the electrochemical conditions that initiate and sustain pits (Fontana, 1986).

Crevice corrosion develops within confined stagnant spaces, including gasketed joints, under sediment deposits, beneath corrosion products, or in any geometry where the bulk fluid cannot freely circulate. Stagnation allows oxygen to be consumed and ionic concentrations to shift until the crevice interior becomes highly aggressive relative to the surrounding surface. The localized attack that results can be severe and is difficult to detect during routine inspection.

2.3 Passivity and Its Relevance to MIC

Several engineering alloys, including stainless steels, aluminum alloys, and titanium, owe their corrosion resistance to the formation of thin, adherent oxide films that kinetically block further oxidation. These passive films, typically only a few nanometers thick, are remarkably effective barriers under benign conditions. However, they are susceptible to breakdown under specific attack. Chloride ions are the most well-known passive film disruptors, but acidic metabolites and sulfide compounds produced by microorganisms can also destabilize passivity locally. This explains why austenitic stainless steels, which perform reliably in many corrosive service environments, have experienced MIC pitting failures in cooling water systems, fire protection piping, and water distribution applications where biofilm activity was not anticipated (Little & Lee, 2007).

2.4 Environmental Factors Governing Corrosion Rate

Temperature increases electrochemical reaction rates according to Arrhenius kinetics, typically roughly doubling reaction rates for every 10°C rise in temperature within moderate ranges. Higher temperatures also accelerate microbial metabolic activity, creating a compounding effect in MIC environments. pH directly influences both cathodic reaction rates and the stability of passive films. Oxygen concentration governs the cathodic reduction rate in neutral and alkaline environments; lower oxygen in bulk fluid does not necessarily mean lower corrosion risk, because oxygen depletion beneath biofilms creates anodic regions that drive aggressive localized attack. Chloride concentration increases electrolyte conductivity and attacks passive films, making seawater and produced water environments particularly corrosive.

Flow velocity has a complex and sometimes counterintuitive relationship with corrosion. Moderate flow generally reduces MIC risk by preventing biofilm establishment and maintaining disinfectant residuals. Very low flow or stagnation, on the other hand, allows sediment to accumulate, oxygen gradients to develop, and microbial communities to attach and grow. At the other extreme, very high velocities can cause erosion-corrosion, stripping protective films and delivering corrosive species to the metal surface at high flux rates. The engineering implication is that systems designed to accommodate wide ranges of flow velocity, or those that experience extended periods of shutdown, require particular attention to microbial risk.

2.5 How Microorganisms Interact with Electrochemical Corrosion

Microorganisms modify nearly every parameter that governs electrochemical corrosion behavior. They consume oxygen within biofilms, creating differential aeration cells in which the oxygen-depleted metal beneath the biofilm becomes anodic relative to adjacent oxygenated surfaces. They produce organic and inorganic acids that lower local pH and increase dissolution rates. Some produce hydrogen sulfide, which attacks iron and some alloy systems through multiple mechanisms simultaneously. Others produce extracellular polymers that concentrate aggressive ions at the metal surface.

Perhaps most significantly, certain microorganisms have been shown to participate directly in electron transfer reactions at the metal surface, effectively short-circuiting the electrochemical cell in ways that conventional corrosion theory did not anticipate. Hamilton (2003) proposed a unifying electron transfer hypothesis suggesting that electroactive microorganisms can use the metal itself

as an electron donor, accelerating anodic dissolution at rates substantially higher than abiotic systems would predict. This mechanism, sometimes called electrical microbially influenced corrosion (EMIC), remains an active area of research and has significant implications for explaining some of the extremely rapid pit penetration rates observed in MIC failures.

The practical engineering takeaway from all of this is that the presence of a biofilm at a metallic surface changes the corrosion environment in ways that cannot be predicted from bulk fluid chemistry alone. The local chemistry beneath a mature biofilm can differ dramatically from the surrounding environment, and it is that local chemistry, not the averaged bulk condition, that governs metal loss.

2.6 Corrosion Rate Measurement and Electrochemical Kinetics

Corrosion rate is the parameter that engineers most often need to quantify when assessing infrastructure condition or selecting mitigation strategies. The most direct expression of corrosion rate for metallic infrastructure is **metal penetration rate**, typically expressed in mils per year (mpy) or millimeters per year (mm/y), which relates directly to the design life remaining at a given location. Electrochemical methods provide complementary rate information and are particularly useful for continuous online monitoring.

Linear polarization resistance (LPR) is the most widely used electrochemical technique for real-time corrosion rate measurement in process systems. It applies a small perturbation to the electrochemical potential of the metal and measures the resulting current response; the ratio of potential to current, the polarization resistance, is inversely proportional to the instantaneous corrosion rate through the Stern-Geary relationship. LPR probes can be installed directly in pipelines, tanks, and process systems to provide continuous corrosion rate data. In biologically active systems, however, LPR measurements require careful interpretation because biofilm impedance can distort the electrochemical response, potentially underestimating the actual metal loss at the biofilm-covered surface. **Electrochemical impedance spectroscopy** (EIS) separates biofilm impedance from metal corrosion response, providing more reliable rate data in systems where biofilm is expected (Revie & Uhlig, 2008).

Gravimetric coupon methods, despite being among the oldest corrosion monitoring techniques, remain valuable because they measure actual metal loss rather than an electrochemical proxy. A coupon installed in a bypass flow loop is exposed to the same environment as the process piping for a defined period, then

removed and weighed. The difference between initial and final weight, normalized by surface area and exposure time, gives the average corrosion rate over the monitoring period.

Coupons can also be submitted for surface analysis, including scanning electron microscopy and energy-dispersive X-ray spectroscopy, to characterize pit morphology and identify corrosion products indicative of MIC. The main limitation is that coupons provide average rates over the exposure interval, and it may not capture episodic events or localized attack that is confined to small areas of the coupon surface.

CHAPTER 3

Microbiology Fundamentals for Engineers

3.1 Why Engineers Need to Understand Microbiology

Engineering education does not typically include microbiology. This was mainly because infrastructure systems were designed around the physics and chemistry of their environments, and microorganisms were considered a biological curiosity rather than a design variable. This has now changed. Biofilm formation, microbial sulfur cycling, and enzymatic metal reduction are now recognized as significant contributors to infrastructure deterioration in multiple sectors, and engineers who cannot recognize the conditions that promote microbial growth are poorly equipped to evaluate MIC risk in the systems they design or manage (Little & Lee, 2007).

The goal is to provide enough microbiological literacy to understand why certain environments are vulnerable, what observable indicators suggest microbial activity, and why some mitigation approaches work while others fail.

3.2 The Principal Microorganisms Associated with MIC

Bacteria are the dominant MIC contributors across most infrastructure environments. They are single-celled organisms capable of reproducing rapidly, adapting their metabolism to changing conditions, and forming protective communities on surfaces (Figure 3). The MIC-relevant bacterial groups are typically classified by their metabolic relationship with sulfur, oxygen, and iron compounds, because it is these metabolic activities that create the corrosive chemical conditions at metal surfaces (Videla, 1996).

Sulfate-reducing bacteria (SRB) are the most widely studied and arguably the most economically significant MIC organisms (Figure 3). They are obligate anaerobes that use sulfate as a terminal electron acceptor in their metabolism, producing hydrogen sulfide as a byproduct. Hydrogen sulfide is corrosive to iron and many alloy systems through multiple mechanisms, including direct chemical attack, cathodic depolarization, and hydrogen embrittlement in high-strength steels (see Figure 4). SRB thrive in oxygen-depleted environments, such as buried pipelines, the interior of biofilms, sedimented tank bottoms, and anaerobic wastewater zones.



Figure 3: Scanning electron microscopy (SEM) images of the sulfate-reducing bacteria (SRB).

Credit: Xia et al., 2024




Figure 4: A schematic view of the function of sulfate-reducing bacteria (SRB) in microbiologically induced corrosion (MIC). Credit: Kiani et al., 2019.

Sulfur-oxidizing bacteria (SOB) operate in the opposite metabolic direction. Given a source of reduced sulfur compounds, typically hydrogen sulfide produced by SRB or released from organic decomposition, SOB oxidize these compounds to elemental sulfur and ultimately produce sulfuric acid. In concrete sewer systems, this sulfuric acid generation process, driven by *Thiobacillus* and related organisms, is responsible for some of the most severe infrastructure deterioration encountered in municipal engineering. SOB are aerobic organisms and colonize the moist surfaces at the air-water interface in sewer pipes, where they have access to both oxygen and the hydrogen sulfide rising from the wastewater below.

Iron-reducing and iron-oxidizing bacteria interact directly with iron compounds and can produce voluminous rust-colored deposits in water systems. Iron-oxidizing bacteria such as *Gallionella* and *Leptothrix* produce sheaths and stalks

encrusted with iron hydroxides. While they are not always primary corrosion agents, their deposits create ideal under-deposit conditions for more aggressive anaerobic organisms. Acid-producing bacteria (APB) generate organic acids through fermentation and other metabolic pathways, lowering local pH and attacking both metal surfaces and cement matrices. Their activity is particularly relevant in industrial process systems where organic nutrients are available.

Archaea, a domain of life distinct from bacteria, include the methanogens and some extremely thermophilic organisms. Certain sulfate-reducing archaea are increasingly recognized as MIC contributors in high-temperature oil and gas systems and deep subsurface environments where conventional bacteria struggle to survive (Javaherdashti, 2008).

Table 2 below lists some of the principal microorganism groups associated with MIC, their metabolic activities, and the environments in which they typically predominate.

Table 2: Principal MIC-Associated Microorganism Groups.

Group	Abbreviation	Metabolic Activity	Primary Byproduct	Typical Environment
Sulfate-reducing bacteria	SRB	Reduces sulfate to sulfide	Hydrogen sulfide (H ₂ S)	Anaerobic soil, biofilm interiors, oil/gas systems
Sulfur-oxidizing bacteria	SOB	Oxidizes sulfide to sulfuric acid	Sulfuric acid (H ₂ SO ₄)	Sewer crowns, wet wells, partially aerated systems
Iron-oxidizing bacteria	IOB	Oxidizes ferrous to ferric iron	Iron hydroxide deposits	Groundwater, water distribution systems
Acid-producing bacteria	APB	Fermentation; organic acid generation	Organic acids	Industrial process systems, nutrient-rich water
Methanogens (Archaea)	MOB	Produces methane from CO ₂ /H ₂	Methane; localized pH change	Deep subsurface, high-temperature reservoirs

3.3 Nutrient Requirements and Environmental Conditions

Microbial growth in engineering systems depends on the availability of nutrients, primarily carbon sources for energy and cell building, nitrogen, phosphorus, and in many cases sulfate or iron compounds as electron acceptors. Most

infrastructure environments contain sufficient nutrients to support some level of microbial growth. Completely eliminating nutrients from a water or process system is generally impractical, which is why operational strategies focus instead on controlling the conditions that allow microbial communities to establish and persist: flow velocity, temperature, stagnation, pH, and disinfectant residuals.

Temperature significantly influences both microbial growth rates and the composition of microbial communities. Most MIC-relevant bacteria are mesophiles, growing most actively between 20°C and 40°C (68°F and 104°F). Thermophilic SRB and archaea extend the MIC risk envelope into high-temperature environments such as in geothermal systems, deep wells, and some industrial processing applications. At very low temperatures, microbial activity slows substantially but does not cease entirely. Biofilms in cold-climate water systems remain capable of MIC even where temperatures approach freezing.

3.4 Microbial Communities and Synergy

In real infrastructure environments, MIC rarely results from a single organism species acting in isolation. Instead, diverse communities of organisms colonize the same surface and interact metabolically in ways that amplify their collective corrosive effect. A layered biofilm might contain aerobic iron-oxidizing bacteria in its outer, oxygen-rich regions creating the deposit conditions that shelter anaerobic SRB in the oxygen-depleted interior. The SRB produce hydrogen sulfide that diffuses back toward the surface, where SOB can oxidize it to sulfuric acid. The acid then attacks both the metal surface and the cement matrix of any concrete infrastructure in the vicinity. This kind of cooperative metabolic cascade means that eliminating a single organism group often provides only partial or temporary relief, because the ecological niche it occupied will typically be recolonized by a functionally equivalent organism given sufficient time.

This ecological perspective has practical implications for mitigation design. Biocide programs that target only SRB, for example, may successfully suppress sulfide generation for a period while leaving the underlying biofilm and the conditions that favor it unchanged. A more effective long-term strategy addresses the environmental conditions that allow the entire microbial community to establish, particularly stagnation, sediment accumulation, and nutrient availability.

3.5 Microbial Growth Kinetics and Infrastructure Implications

Understanding the basic principles of microbial growth helps engineers predict how quickly biological communities develop in infrastructure systems under different environmental conditions. Microbial populations grow exponentially under favorable conditions, doubling at intervals that range from 20 minutes for fast-growing organisms such as *Escherichia coli* in optimal conditions, to many hours or days for slow-growing organisms like some SRB species in low-temperature, nutrient-limited environments. This exponential growth characteristic means that a small initial population can become a substantial biofilm community in days to weeks given adequate nutrients, moisture, and temperature.

In engineering systems, the most significant growth-limiting factors are typically nutrient availability, disinfectant residual concentration, and the hydrodynamic conditions at the surface. When all three constraints are simultaneously present, for example in a poorly maintained system that has experienced a treatment interruption combined with low summer flow velocities and elevated temperatures, the conditions for rapid biofilm development can produce significant internal corrosion activity within a single season. It is therefore important for engineers managing infrastructure through operational changes to assess MIC risk as part of any decision that materially alters flow velocity, treatment, or temperature in a system with established biofilm history.

The concept of minimum biofilm eradication concentration (MBEC) is relevant to biocide program design. The MBEC is the minimum biocide concentration required to kill all organisms within a biofilm. It is distinct from the minimum inhibitory concentration (MIC) for planktonic cells (unfortunately it shares the same MIC abbreviation as microbially induced corrosion, but the context should make it clear which is meant). In practice, MBEC values for established biofilm communities are typically 100 to 1,000 times higher than planktonic MIC values for the same biocide. This explains why biocide doses that are effective against free-swimming organisms in bulk water fail to eradicate established biofilm. Shock treatment programs that briefly raise biocide concentrations to MBEC levels, combined with physical cleaning to remove the biofilm mass, are far more effective at biofilm eradication than continuous low-level dosing at concentrations below the MBEC.

CHAPTER 4

Biofilm Formation and Microbial Community Dynamics

4.1 What Is a Biofilm

A biofilm is a structured community of microorganisms attached to a surface and enclosed within a self-produced matrix of extracellular polymeric substances (EPS; Figure 5). The EPS matrix is composed of polysaccharides, proteins, nucleic acids, and lipids, and it performs several functions simultaneously:

- It anchors the community to the surface, retains water and nutrients
- Concentrates enzymes at the site of activity
- Provides mechanical protection against shear forces and chemical attack.

Biofilms are not simply random accumulations of cells. They are organized communities with distinct spatial architecture, communication systems, and metabolic division of labor (Characklis & Marshall, 1990).




Figure 5: Stage of Biofilm Formation.

Credit: Hindieh et al., 2025

The distinction between planktonic (free-floating) and biofilm-associated organisms is essential for understanding MIC. Planktonic bacteria in a water sample are relatively easy to count, study, and treat with biocides. Biofilm organisms are another matter entirely. Within the EPS matrix, cells may be 100 to 1,000 times more resistant to biocide treatment than their planktonic

counterparts, and the chemical conditions they create at the metal surface beneath them can be radically different from the bulk fluid chemistry measured in a pipe sample. A water analysis showing acceptable chemistry does not exclude MIC risk if biofilm is present on the pipe wall.

4.2 Stages of Biofilm Development

Biofilm development follows a recognizable sequence that is worth understanding in engineering terms because each stage creates different intervention opportunities (see Figure 5 above). Initial attachment begins within hours of surface exposure when planktonic cells, carried to the surface by flow or diffusion, make reversible contact with the substrate. Surface roughness, surface energy, and the presence of a conditioning film of adsorbed organic molecules all influence how readily cells attach. Once cells transition from reversible to irreversible attachment, typically within hours to days, removal requires physical force.

The early attachment phase is followed by microcolony formation and growth, during which the attached cells begin producing EPS and recruiting additional organisms. As the biofilm matures, spatial differentiation develops. Distinct microbial populations occupy different niches based on oxygen availability, pH, and nutrient gradients. In a mature biofilm on a steel pipe, the outer surface may be occupied by aerobic organisms that consume incoming oxygen, while the inner layers, directly adjacent to the metal, become anoxic environments populated by anaerobic SRB. The oxygen gradient through the biofilm is typically steep; dissolved oxygen can drop from ambient levels to near zero within a few hundred micrometers of the metal surface. Dispersal, the final stage, involves the deliberate release of cells from the mature biofilm into the bulk fluid, allowing colonization of new surfaces downstream. This dispersal mechanism is one reason MIC tends to spread through piping networks rather than remaining confined to a single location.

4.3 Electrochemical Significance of Biofilms

The engineering importance of biofilms in MIC stems from their capacity to establish highly aggressive local chemical environments directly at the metal surface, environments that can differ dramatically from the surrounding bulk fluid. The oxygen gradient described above creates a classic differential aeration cell, where the oxygen-depleted metal beneath the biofilm becomes anodic relative to adjacent oxygenated areas, and material loss concentrates at the covered surface. This is the under-deposit corrosion mechanism operating on a

microscopic scale and driven by biological rather than physical deposit formation.

Sulfide production by SRB within the anaerobic biofilm interior adds a further layer to this localized environment. Hydrogen sulfide reacts directly with iron to form iron sulfide, which is electrochemically more noble than the surrounding steel, and, therefore, drives galvanic attack. Iron sulfide deposits have been identified in pit corrosion products in numerous documented MIC failures, and their presence during metallurgical examination is one of the diagnostic indicators of SRB activity (Borenstein, 1994). Additionally, the acidic metabolites produced within the biofilm lower the local pH, further destabilizing passive films and increasing dissolution rates.

Flemming (2002) observed that biofilm-covered surfaces in industrial water systems effectively function as biological reactors, continuously processing the passing fluid and concentrating its reactive components at the metal's surface. From a corrosion engineering standpoint, this means the metal is not being attacked by the bulk fluid, but by the concentrated, metabolically active product of the biofilm ecosystem.

4.4 Conditions That Favor Biofilm Formation

Low or intermittent flow is the single most reliable predictor of biofilm establishment risk. High-velocity turbulent flow inhibits initial cell attachment and periodically detaches developing biofilms. Systems designed for intermittent operation, including fire protection piping, seasonal cooling water circuits, and standby equipment, are therefore at higher risk than continuously operated systems at moderate flow. Stagnation in dead-leg piping sections, oversized distribution networks, and abandoned branches all provide ideal conditions for biofilm development.

The condition of the surface also matters. New pipe surfaces with smooth, clean walls will resist initial colonization better than old, roughened, or pitted surfaces. Internal corrosion deposits, weld root anomalies, and scratch marks from cleaning all provide preferential attachment sites. Once a biofilm establishes in these locations, it is essentially self-perpetuating as long as nutrients and moisture remain available.

Temperature, nutrient concentration, and the presence or absence of a disinfectant residual complete the picture. Systems with adequate and consistent chlorine or chloramine residuals suppress biofilm growth in bulk areas, however, they may still experience localized biofilm development in stagnation zones

where residuals decay. Understanding these spatial patterns within a distribution network or process system is central to identifying where MIC risk is concentrated.

4.5 Detection and Characterization of Biofilm in Engineering Systems

Detecting the presence and assessing the extent of biofilm in operating infrastructure is considerably more difficult than studying biofilm in a laboratory setting. Most biofilm detection in the field relies on indirect indicators rather than direct observation. In water distribution systems, heterotrophic plate counts (HPC) from water samples give a proxy for the general microbial activity in the system. Persistently elevated HPC values in specific system zones suggest elevated biofilm activity at those locations. Pipe sections removed during maintenance or repair allow direct visual inspection of the internal surface, and the characteristic rust-colored or black deposits associated with iron bacteria or SRB activity are recognizable with some experience. However, selective section removal is impractical as a systematic survey method for large networks.

Corrosion coupons installed at representative system locations provide the most practical ongoing biofilm monitoring in most infrastructure applications. At the end of each exposure interval, coupons retrieved for weight loss measurement can also be examined by scanning electron microscopy to characterize biofilm morphology, and by energy-dispersive spectroscopy to identify elemental composition of the corrosion products. The presence of sulfur in pit interiors, for example, is a strong indicator of SRB involvement even when microbiological culture has not been performed on the coupon surface directly. Adenosine triphosphate (ATP) bioluminescence assays provide a rapid field measurement of total microbial biomass in water samples or coupon surface swabs. ATP is present in all living cells and decays rapidly in dead organisms, making ATP concentration a reliable measure of living microbial mass rather than total cell count including dead cells.

Differential pressure monitoring across sections of a distribution network or cooling system provides a practical indicator of biofilm accumulation and tuberculation even without any direct biological measurement. As biofilm develops and deposits accumulate on pipe walls, the effective flow area decreases, and head loss increases. Trend analysis of pressure drop data, when plotted against flow rate over time, reveals gradual increases in hydraulic resistance that indicate progressive internal fouling. While this method cannot distinguish MIC-related deposit formation from mineral scaling or other fouling mechanisms without supplementary investigation, it provides a sensitive and

continuous early-warning indicator that can trigger more targeted inspection before significant wall loss has occurred.

CHAPTER 5

Microbial Corrosion Mechanisms: Sulfate-Reducing Bacteria, Acid Producers, and Anaerobic Environments

5.1 Sulfate-Reducing Bacteria and Anaerobic Corrosion

Sulfate-reducing bacteria (SRB) represent the most extensively documented and economically significant organism group in MIC. Their relevance spans buried pipelines, oil and gas production systems, marine structures, water distribution networks, and industrial processing facilities.

SRB are obligate anaerobes, meaning they require an oxygen-free environment to function. They obtain energy by using sulfate ions as the terminal electron acceptor in their metabolic process, reducing sulfate to hydrogen sulfide (see Figure 6). This reduction does not occur at normal water temperatures without biological catalysis, which makes SRB the essential mediator of the sulfate-to-sulfide transformation in anaerobic engineering environments (Videla & Herrera, 2005).




Figure 6: Mechanism of microbiologically influenced corrosion (MIC) of iron by sulfate-reducing bacteria (SRB). Credit: Tripathi et al., 2021.

The corrosive consequences of SRB activity are multiple. Hydrogen sulfide reacts with iron to produce iron sulfide, a compound that is electrochemically more noble than iron in most environments, creating a galvanic couple that drives

anodic dissolution of the surrounding steel. In high-strength steel pipelines and pressure vessels, hydrogen sulfide can also promote sulfide stress cracking and hydrogen embrittlement, mechanisms in which atomic hydrogen generated at the cathode diffuses into the metal lattice and causes brittle fracture at stress concentrations well below the material's nominal yield strength. This mechanism has contributed to catastrophic failures in downhole tubing, wellheads, and high-pressure pipeline systems in sour service environments.

The classical electrochemical explanation for SRB-accelerated corrosion, the cathodic depolarization theory proposed by von Wolzogen Kühr and van der Vlugt in the 1930s, stated that SRB consume the atomic hydrogen that would otherwise accumulate at the cathode and slow the corrosion reaction. By consuming this hydrogen, SRB depolarize the cathodic surface and allow corrosion to continue at an elevated rate. While this mechanism remains conceptually useful, more recent research has expanded the picture considerably. Direct electron uptake from the metal surface, extracellular electron transfer, and the formation of conductive iron sulfide networks within the biofilm are all now recognized as contributing mechanisms in anaerobic MIC (Hamilton, 2003).

5.2 Acid-Producing Microorganisms

Acid-producing bacteria generate corrosive conditions through organic and inorganic acid production rather than sulfide generation. This category includes a diverse range of fermentative organisms that produce acetic acid, formic acid, butyric acid, and other short-chain organic acids as metabolic byproducts. While each acid is relatively weak in isolation, the cumulative effect of continuous acid production within a biofilm directly adjacent to a metal surface can maintain a highly aggressive local pH regardless of the neutral or alkaline bulk fluid chemistry.

The most consequential acid-producing process in infrastructure engineering is biological sulfuric acid generation, carried out by sulfur-oxidizing bacteria in aerobic wastewater environments. In sewer systems, the metabolic cycle begins with anaerobic SRB generating hydrogen sulfide in the flowing wastewater or sediment layer (see Figure 7). This gas migrates into the headspace above the waterline, where it contacts the moist concrete surface of the sewer crown. *Thiobacillus thiooxidans* and related SOB, which are capable of growth at pH values below 1.0, colonize this surface and oxidize the hydrogen sulfide to sulfuric acid. The acid attacks calcium silicate hydrates and calcium aluminate hydrates in the cement matrix, progressively converting the concrete to a soft, powdery gypsum-

like mass with virtually no structural integrity. In the most aggressive environments, sewer crowns have been observed losing several millimeters of concrete per year, leading to structural collapse within the design service life of the infrastructure (U.S. EPA, 2002).




Figure 7: Schematic representation of the corrosion process within a sewer. Sulfate-reducing bacteria (SRB) produce hydrogen sulfide (H_2S) in the liquid phase, which escapes to the gas phase. Sulfur-oxidizing bacteria (SOB) convert H_2S into sulfuric acid, causing pipe corrosion.

Credit: Tasaduq et al., 2025.

5.3 Anaerobic Corrosion Environments

Anaerobic conditions are not inherently prerequisite for MIC to occur, but many of the most severe MIC environments share the characteristic of oxygen depletion, either in the bulk environment or within the biofilm interior. Oxygen-depleted zones concentrate the activity of the most aggressive MIC organisms, particularly SRB, while simultaneously creating the differential aeration cells that drive localized electrochemical attack.

Buried pipelines represent a classic anaerobic MIC environment. Soil anaerobiosis develops when microbial oxygen consumption in the surrounding soil exceeds the rate of oxygen diffusion from the atmosphere, a condition common in clay-rich, waterlogged, or organically rich soils. External SRB colonization of pipeline surfaces in anaerobic soils has caused numerous severe failures across multiple continents and sectors (see Figure 8). This is due to the coating holidays in clay-rich or waterlogged soils that allow SRB direct access to

bare steel, and the resulting localized pitting can penetrate full pipe wall thickness within a few years under aggressive biological conditions (Javaherdashti, 2008; Little & Lee, 2009). Cathodic protection provides a degree of mitigation in these environments, but if coating defects allow biofilm to establish at the bare metal surface, the interaction between cathodic protection current and SRB metabolism creates additional complexity that requires careful engineering analysis.



Figure 8: Large pits and perforations were seen on the surface of a steel pipe elbow.

Credit: Kiani et al., 2019.

Oil and gas produced water systems routinely encounter sulfate-rich formation waters under anaerobic conditions, creating near-ideal SRB growth environments. Water accumulation at low points in gathering pipelines creates persistent anaerobic pockets, and the produced water itself may contain abundant sulfate from geological sources. Documented SRB-related internal pitting failures in Gulf of Mexico and North Sea pipeline systems have cost operators substantial remediation expenditure and, in some cases, triggered regulatory inspection programs for entire pipeline networks.

5.4 Diagnosis of SRB and Acid-Producing Corrosion

Distinguishing MIC-related pitting from abiotic localized corrosion during failure investigation requires evidence beyond the corrosion morphology itself. The presence of black iron sulfide corrosion products in pit interiors is a strong indicator of SRB activity, though iron sulfide can form through purely chemical reactions in sour environments without biological involvement.

Microbiological culturing of samples taken from pit surfaces, corrosion products, and adjacent biofilm provides more direct evidence of SRB presence, though

culture methods notoriously undercount viable populations because many organisms do not grow well under laboratory conditions. Molecular techniques, including quantitative polymerase chain reaction (qPCR) analysis targeting SRB-specific genetic markers, provide a more sensitive and accurate assessment of microbial populations and are increasingly used in engineering investigation protocols for suspected MIC failures.

A comprehensive MIC failure investigation typically combines metallurgical examination of the corroded surface, microbiological sampling and analysis, water chemistry assessment, and a review of operational history for conditions that would promote biofilm development. The combination of evidence from multiple analytical approaches provides much stronger grounds for MIC attribution than any single test in isolation.

5.5 Electrical MIC and Direct Electron Transfer

A significant development in the understanding of anaerobic MIC has been the recognition that certain microorganisms can extract electrons directly from metallic iron without the intermediate production of hydrogen or the involvement of corrosive metabolites at all. This mechanism, variously termed electrical MIC (EMIC) or extracellular electron transfer, involves organisms that are capable of using the metal surface itself as an electron donor in their respiratory metabolism. Rather than consuming a dissolved substrate, these electroactive organisms oxidize iron directly at the metal surface and transfer the electrons to their metabolic electron transport chain through conductive protein filaments, iron sulfide conductive networks within the biofilm, or direct enzymatic contact with the metal surface.

The engineering implication of EMIC is significant. Corrosion rates associated with direct electron transfer can substantially exceed those predicted by classical cathodic depolarization models. This would potentially explain some of the extremely rapid wall penetration rates observed in SRB-related pipeline failures where the observed damage far exceeded what abiotic hydrogen sulfide attack alone would produce. It has been shown that the corrosion rates in EMIC-active systems were an order of magnitude higher than in systems where SRB were active but direct contact with the metal was precluded (Javaherdashti, 2008). While this remains an active area of research, and the relative contribution of EMIC versus other SRB mechanisms varies by system, it provides an important caution against assuming that any single mechanism fully accounts for the corrosion observed in anaerobic MIC environments.

From a practical standpoint, EMIC mechanisms are particularly relevant in systems where the biofilm is directly attached to the metal surface with intimate contact, as opposed to systems where the biofilm is separated from the metal by a coating, scale, or thick deposit layer. This distinction reinforces the importance of coating integrity and the management of deposit formation as primary MIC prevention measures in anaerobic environments.

CHAPTER 6

MIC in Water, Wastewater, and Building Systems

6.1 Water Distribution Systems

Municipal water distribution systems are often assumed to be relatively clean environments because treated water contains chlorine or chloramine disinfectants. In practice, most distribution systems still harbor some level of microbial activity, and under the right conditions, biofilm communities capable of driving MIC develop even in compliant systems. As water travels through an extensive distribution network, residual disinfectant decays, temperatures rise during warm months, and organic carbon accumulates. In hydraulic dead zones, oversized pipe sections, and storage tank inlets, water age can become high enough to allow substantial biofilm growth before water reaches the end user. The resulting biofilm communities on iron or ductile iron pipe walls can produce tuberculation, a characteristic mound-like corrosion deposit that contains iron oxides, iron bacteria, and embedded anaerobic organisms (American Water Works Association, 2012; see Figure 9).




Figure 9: Heavily corroded internal surface of cast iron pipe used in drinking water distribution systems. (a) Pipe cross section, (b) tubercle. Credit: Mi et al., 2015

Tuberculation illustrates how infrastructure geometry interacts with microbial activity. As tubercles grow, they restrict flow area and increase head loss (see Figure 9 (b)). More significantly, the oxygen-depleted zone directly beneath each tubercle becomes anodic, concentrating corrosion at exactly the points where the deposit has formed. Older cast iron mains in many US cities exhibit severe

tuberculation that has measurably reduced hydraulic capacity and produced localized pipe wall losses far exceeding the original corrosion allowance. The corrosion is not always immediately visible from the outside because the external pipe surface may remain intact while the internal wall progressively thins.

Fire protection systems deserve specific attention because they represent one of the highest-risk MIC environments in building infrastructure. Wet-pipe sprinkler systems, standpipes, and fire suppression loops often sit filled with stagnant water for years between tests, receiving no regular flow and no disinfectant replenishment. Oxygen is gradually depleted, iron bacteria colonize the surfaces, and SRB establish in the oxygen-depleted lower reaches of the system. The result is pinhole leaks, sludge accumulation, and flow blockage in sprinkler heads that may go undetected until a fire event reveals that the system no longer functions as designed. NACE International (2016) provides specific guidance on MIC assessment in fire protection systems, recognizing the sector as a priority application.

6.2 Wastewater Infrastructure

Wastewater systems are among the most biologically aggressive environments in civil engineering. The combination of abundant organic matter, sulfate from household and industrial sources, warm temperatures, and alternating aerobic and anaerobic conditions creates near-ideal conditions for the sulfur-cycling microbial communities responsible for concrete crown corrosion and metal fitting deterioration.

The sulfur cycle in a gravity sewer operates as follows:

- Sulfate in the wastewater is reduced to hydrogen sulfide by SRB in the anaerobic portions of the flow, particularly in force main outlets, sedimented inverts, and stagnant wet wells.
- The hydrogen sulfide gas partitions into the sewer headspace, where it contacts the moist concrete crown surface above the waterline.
- SOB growing on that surface oxidize the gas to sulfuric acid at concentrations that can reduce the surface pH to below 2.0. At this pH, the calcium silicate and calcium aluminate compounds in ordinary Portland cement dissolve, and the concrete effectively disintegrates from the inside out (U.S. EPA, 2002).

The engineering consequences are severe. MIC in concrete sewers has been documented by investigators across multiple countries and infrastructure

contexts. Little and Lee (2009) report estimates that biodegradation is the primary driver of concrete deterioration in wastewater collection and treatment systems, with annual expenditure for replacement of manholes, wet wells, concrete pipes, treatment facilities, and grit chambers exceeding \$100 million in the United States alone.

Force mains, which convey wastewater under pressure in a filled-pipe anaerobic condition, are particularly susceptible to sulfide generation and to MIC on internal metal fittings. Long force mains with high retention times allow sulfide concentrations to build to several mg/L by the time the wastewater discharges into a receiving manhole. The sudden aeration at the discharge point produces intense sulfide release and acid generation at the exact location where turbulence tends to strip any protective film from concrete and metal surfaces.

6.3 Building Mechanical Systems: HVAC and Cooling Towers

Heating, ventilation, and air conditioning systems, and particularly cooling towers, present a distinct MIC environment characterized by warm temperatures, circulating water, and the constant introduction of atmospheric microorganisms. Cooling towers operate by evaporating a fraction of the circulating water to reject heat, which concentrates dissolved minerals, nutrients, and microorganisms in the remaining water. Without effective treatment, this concentration process creates conditions highly favorable for biofilm development on heat exchanger surfaces, distribution headers, and fill media.

The public health dimension of cooling tower microbiology extends beyond corrosion. *Legionella pneumophila*, the organism responsible for Legionnaires disease, grows in biofilms in cooling towers and other water systems, and can be dispersed as infectious aerosols when the tower operates. The ASHRAE Standard 188 risk management framework, as well as various state and local regulations, now require documented water treatment and monitoring programs for cooling towers to reduce this risk. From a corrosion engineering standpoint, the same biofilm control measures that suppress *L. pneumophila* also reduce MIC risk in the cooling system, making the public health and infrastructure protection goals closely aligned.

Chilled water systems and closed-loop HVAC circuits are somewhat less vulnerable to MIC than open cooling towers because they are not continuously exposed to atmospheric microbial introduction. However, intermittent or seasonal systems that sit stagnant during off seasons are at risk for the same reasons that fire protection systems are; biofilm communities develop during

stagnation and may drive localized corrosion that only becomes apparent when the system is returned to service.

6.4 MIC Risk Factors in Building Plumbing Systems

Building plumbing systems, including domestic hot and cold water distribution, process water circuits, and in-building fire protection networks, present a set of MIC risk factors somewhat different from those in large utility or industrial infrastructure. The primary distinction is scale. Building systems are typically smaller in diameter, have more complex geometries, and experience more variable demand patterns than utility networks. These characteristics create numerous stagnation zones, particularly in oversized piping in low-occupancy commercial buildings, in seasonal facilities that are shut down for months at a time, and in the terminal sections of large-diameter institutional distribution systems where flow is intermittent.

The transition to newer plastic piping materials in building construction, including cross-linked polyethylene (PEX) and chlorinated polyvinyl chloride (CPVC), has reduced MIC risk for the piping itself, but metallic fittings, valves, and heat exchangers are still used in most systems and remain vulnerable. Brass fittings in contact with biofilm-active water can experience dezincification, a form of selective corrosion in which zinc is preferentially removed from the brass matrix, leaving a porous copper residue with poor mechanical properties. While dezincification is primarily a chemical rather than a biological process, the acidic local environment created by acid-producing bacteria in a biofilm can accelerate its rate.

The management of *L. pneumophila* risk in building water systems, now a regulatory requirement in many jurisdictions under ASHRAE Standard 188 water management programs, has had the beneficial secondary effect of improving overall MIC control in these systems. A water management program that establishes effective temperature controls, maintains adequate disinfectant residuals, identifies and flushes low-use outlets, and conducts regular system inspections, addresses the same conditions that promote MIC biofilm development. Buildings that have implemented ASHRAE 188-compliant programs generally show better overall internal corrosion performance in their metallic components than those relying on passive maintenance approaches.

CHAPTER 7

MIC in Pipelines, Storage Tanks, and Industrial Facilities



7.1 Pipelines: Internal and External MIC

Pipelines present MIC risk on both their internal and external surfaces, and the mechanisms differ significantly enough that they warrant separate engineering assessment. Internal MIC develops when the transported fluid contains water, whether as the primary product or as a contaminant, along with sufficient nutrients and the absence of conditions that would prevent microbial growth. External MIC develops where buried pipelines encounter anaerobic soils containing SRB, an environment that is common in marine sediments, waterlogged clay soils, and areas influenced by organic waste disposal.

Internal pipeline MIC is most severe in systems that carry water-contaminated hydrocarbons or produced water. In liquid hydrocarbon pipelines, even small quantities of water settling at low points create confined, oxygen-depleted zones where SRB flourish. The water-hydrocarbon interface becomes a concentrated microbial environment, and pitting corrosion can develop on the lower internal surface of the pipe, directly beneath the water layer. In the Prudhoe Bay field in Alaska, BP experienced severe internal corrosion on a section of the oil transit pipeline in 2006 that resulted in a significant crude oil spill (U.S. DOT, 2007). Investigation attributed the corrosion in part to the accumulation of produced water in a portion of the pipeline where pigging frequency had been reduced, creating a stagnant environment favorable for internal MIC. The incident resulted

in pipeline shutdown, extensive inspection of adjacent sections, and regulatory enforcement actions.

External MIC in buried pipelines interacts with the cathodic protection (CP) system in ways that are not always straightforward to analyze. CP applies a small protective current to the pipe surface that maintains the metal at a potential where oxidation is suppressed. SRB in the surrounding soil, however, can produce hydrogen sulfide that corrodes the pipe at CP holiday locations, and some research suggests that SRB can interfere with CP effectiveness by altering the local electrochemistry at the metal surface. Coating integrity is, therefore, particularly important in soils with high SRB activity, as the coating is the primary barrier between the anaerobic soil environment and the pipe steel.

7.2 Storage Tanks

Storage tanks are inherently susceptible to MIC because their design creates several conditions favorable to microbial growth. This includes stagnant water accumulation at the tank bottom, thermal stratification in the stored fluid, large surfaces with minimal flow-induced shear, and sediment accumulation over years of operation. In crude oil and fuel tanks, even small quantities of water that separate from the product create a microbially active layer at the bottom of the tank that can drive severe localized corrosion. Tank bottom pitting failures are a well-documented failure mode in petroleum storage facilities, and MIC has been identified as a contributing mechanism in many of these failures (Videla, 1996).

Water tanks and fire protection reservoirs face a different but equally significant challenge. Unlike fuel tanks, they are intended to contain water, but if circulation is inadequate, nutrient concentrations build, disinfectant residuals decay, and biofilm communities establish on internal surfaces. Elevated tanks and reservoirs with long residence times are common sites for MIC-related internal corrosion of steel linings and structural elements. Internal coatings in water storage tanks require regular inspection, and AWWA standards specify coating types and inspection frequencies specifically because coating failure creates the bare metal surface on which MIC can initiate.

7.3 Industrial Processing Facilities

Industrial plants present a diverse array of MIC environments because they combine process water, chemicals, heat, and complex piping geometries in configurations that often create the stagnation and nutrient availability that favor biofilm growth. Heat exchangers are particularly vulnerable because the

temperature differential across the tube bundle creates thermal gradients that can establish stratified flow, and the warm, nutrient-rich water on the cooling side provides ideal conditions for biofilm development on tube surfaces. Even a thin biofilm on a heat exchanger tube imposes a meaningful thermal resistance penalty and, over time, drives localized pitting that eventually penetrates the tube wall, contaminating the process side.

Dead legs in industrial piping systems, sections of pipe installed for future connections or redundancy that see no regular flow, are recognized as one of the most problematic MIC risk factors in process facilities. Dead legs accumulate stagnant fluid, are not reliably cleaned by flushing operations, and may be excluded from inspection programs because they are considered inactive. Best practice in modern industrial plant design calls for identifying and minimizing dead legs, and where they cannot be avoided, establishing regular flushing and inspection protocols. Several industrial insurance underwriters now include dead leg management in their corrosion control requirements for insured facilities.

CHAPTER 8

Marine and Offshore Microbial Corrosion



8.1 The Marine Microbial Environment

Marine environments are simultaneously among the most electrochemically aggressive and the most biologically active environments that engineered structures encounter. Seawater contains approximately 35 g/L of dissolved salts, predominantly sodium chloride. This gives it a high electrical conductivity that reduces the ohmic resistance of the electrochemical corrosion cell and allows corrosion currents to flow over relatively long distances. Dissolved oxygen in surface seawater supports aerobic microbial communities in abundance, while anaerobic conditions predominate in sediments and in the lower reaches of splash zones and tidal regions. The result is that marine structures face both aerobic surface corrosion above the waterline, and anaerobic MIC from SRB in the submerged and buried zones simultaneously.

Seawater also contains an extraordinary diversity of microorganisms. A milliliter of coastal seawater may contain a million or more bacterial cells, and marine sediments are even more densely populated. Biofouling, the accumulation of organisms on submerged surfaces, begins within hours of immersion and follows a predictable succession. It starts with a conditioning film of organic molecules, then bacterial colonization, then the attachment of larger organisms such as barnacles, mussels, and algae. From a corrosion engineering perspective, the bacterial biofilm that forms in the earliest stages of this succession is the layer

that drives MIC, and the macro-fouling community that develops later can complicate inspection and make coating maintenance more difficult.

8.2 MIC in Offshore Structures and Pipelines

Offshore platforms, subsea pipelines, and marine energy infrastructure face MIC in the submerged zone, at the mud-line, and in the internal process systems. The mud-line zone, where a pile or pipeline transitions from free-seawater exposure to burial in marine sediment, is particularly aggressive because it combines the high conductivity of seawater with the anaerobic SRB-rich sediment environment. Cathodic protection systems are designed with this zone in mind, but coating defects and anode depletion at mid-life can expose bare metal to conditions where both abiotic and microbial corrosion are operating simultaneously.

Subsea flowlines in oil and gas fields face internal MIC risk comparable to their onshore counterparts, with the additional complication that inspection access is extremely limited and intervention is costly. Documented MIC failures in North Sea subsea pipelines during the 1980s and 1990s prompted NACE International to develop specific guidance on biocide injection strategies and programs for internally coated subsea lines. The lessons from these failures have been incorporated into modern subsea integrity management frameworks, though the basic vulnerability persists wherever produced water is present in an oxygen-depleted flow regime.

8.3 Concrete and Structural Steel in Marine Applications

Marine concrete structures, including piers, seawalls, jetties, and offshore platform jacket legs, are vulnerable to a combination of chloride-driven reinforcement corrosion and biologically influenced concrete degradation. The tidal and splash zones of concrete structures experience periodic wetting and drying that drives chloride penetration, and the warm, biologically rich conditions in tropical and subtropical coastal environments accelerate biofilm colonization of concrete surfaces. Certain marine organisms, including sulfate-reducing bacteria in anaerobic sediment pockets adjacent to concrete surfaces, can generate acidic conditions locally that accelerate deterioration of the concrete matrix.

Structural steel in marine applications relies on coatings, cathodic protection, and corrosion allowances as the primary defense against deterioration. MIC complicates this because biofilm can establish beneath coating holidays and

drive pitting in locations where CP current is shielded from the metal surface by the biofilm deposit. Inspection programs for marine steel structures, that include biological sampling alongside conventional thickness measurements and potential surveys, provide a more complete assessment of degradation risk than electrochemical methods alone.

8.4 Cathodic Protection and MIC in Marine Systems

Impressed current cathodic protection (ICCP) and sacrificial anode cathodic protection (SACP) systems are standard components of corrosion management programs for marine structures and offshore pipelines. Their interaction with MIC environments in seawater and marine sediment introduces considerations beyond those addressed in terrestrial CP applications. At protected potentials, the cathodic reduction reactions at the metal surface consume oxygen and produce hydroxyl ions, raising the local pH immediately adjacent to the metal. This alkaline micro-environment suppresses many aerobic MIC organisms but does not necessarily inhibit anaerobic SRB deeper in the sediment, where CP current density may be insufficient to maintain the full protective potential due to current shielding by overlying sediment and biofilm layers.

Disbonded coatings on marine pipelines create particularly problematic conditions for CP effectiveness in MIC environments. When a coating disbonds from the pipe surface, the gap between the coating and the metal traps water and sediment in an oxygen-depleted space where CP current cannot penetrate effectively. SRB colonize this shielded space, and can drive severe under-film pitting corrosion at rates that the CP system is unable to arrest because the protective current literally cannot reach the metal through the insulating disbonded coating. This failure mode, sometimes called shielded corrosion or CP shielding, has been responsible for significant pipeline integrity incidents. It is a primary driver of the increasing use of high-resolution inline inspection tools capable of detecting coating disbondment before it leads to pitting penetration.

Marine structures in the tidal and splash zone present a particularly challenging CP design problem. This is because the alternating wet and dry conditions mean the structure is cathodically protected during immersion but unprotected during air exposure. Coatings are the primary protection strategy in this zone, supplemented by CP for any periods of immersion. Where coatings deteriorate, the biological community in the splash zone, which includes a diverse aerobic corrosion-relevant community adapted to the wet-dry cycle, can drive localized attack at coating defects. Regular inspection and coating maintenance in the

splash zone are more critical to long-term structural integrity than the CP system design, which cannot compensate for extensive coating failures in this zone.

CHAPTER 9

Materials Selection, Inspection, and Monitoring

9.1 Materials Selection for MIC Resistance

Materials selection for environments where MIC risk is significant requires consideration of both conventional electrochemical corrosion resistance and susceptibility to biological attack. These two criteria do not always point toward the same material choice. Table 3 shows the general MIC susceptibility ratings by material by the environment.

Table 3: Materials Susceptibility to MIC by Environment.

Material	Water Distribution	Wastewater / Sewer	Marine	Oil & Gas Produced Water
Carbon steel	High	High	High	High
Cast / ductile iron	High (tuberculation)	High	High	Moderate
Austenitic stainless steel (304/316)	Moderate (pitting risk)	Moderate	Moderate	Moderate
Copper alloys	Low to moderate	Moderate	Moderate	Low
Reinforced concrete	Low (unless cracked)	High (crown corrosion)	Moderate	Low
HDPE / polymeric	Negligible	Low	Low	Low

Note: Ratings reflect typical conditions and should not substitute for site-specific assessment.

Austenitic stainless steels, such as 316L and 304, perform reliably in many chemically aggressive environments but have experienced MIC pitting failures in cooling water systems and fire protection piping where biofilm was allowed to establish. The passive film that provides stainless steel its corrosion resistance can be locally destabilized by sulfide compounds and acidic metabolites produced within the biofilm interior, creating pitting initiation sites that then propagate by conventional electrochemical mechanisms (Little & Lee, 2007).

Carbon steel and ductile iron are the most widely used materials in water distribution and pipeline infrastructure, and their susceptibility to MIC is well established. Design specifications for these materials in MIC-prone environments typically include corrosion allowances, internal lining requirements, and cathodic protection provisions. However, the adequacy of these provisions depends on assuming a baseline corrosion rate that may be exceeded if biofilm

activity is more aggressive than anticipated. Copper alloys are generally more resistant to MIC than ferrous metals in potable water applications because copper ions have inherent antimicrobial properties, but they are not immune. Certain SRB-dominated biofilms have been associated with pitting of copper distribution piping in poorly maintained systems.

High-density polyethylene (HDPE) and other polymeric pipe materials are not susceptible to electrochemical corrosion, but they can experience biofouling. Microorganisms colonizing their surfaces may contribute to degradation of rubber gaskets, lubricants, and other organic components within the system. The choice of HDPE for aggressive MIC environments may eliminate the primary corrosion mechanism while introducing a different set of material performance considerations.

9.2 Inspection Technologies for MIC Detection

Detecting MIC requires a combination of physical inspection for corrosion damage, microbiological sampling to confirm biological involvement, and analytical chemistry to characterize the corrosive environment. No single inspection method provides definitive MIC diagnosis on its own; the evidence from multiple approaches must be assembled to support a reliable conclusion.

Internal pipe inspection tools, commonly called inline inspection tools or smart pipe inspection gauges (PIGs), use magnetic flux leakage or ultrasonic measurement to detect wall thinning and pitting from within a flowing pipeline (see Figure 10). These tools can identify localized pitting consistent with MIC, but they cannot distinguish biologically driven pitting from abiotic localized corrosion based on geometry alone. The distribution pattern of pitting, its location relative to low points where water might accumulate, and the morphology of the pit interior during excavation and visual examination provide additional diagnostic context.

Ultrasonic thickness testing (UTT) applied from the external surface is widely used for tanks, vessels, and accessible piping sections. It is particularly valuable for tracking the rate of wall loss over time, which can indicate whether corrosion is progressing at a rate consistent with conventional corrosion assumptions or substantially faster; a pattern that warrants investigation for biological involvement. Guided wave ultrasonic testing allows screening of longer pipeline sections from a single transducer location, making it useful for prioritizing which sections warrant more detailed intrusive inspection.



Figure 10: Smart Pipe Inspection Gauge (PIG).
Credit: John & Mubarak, 2022

Microbiological sampling provides the most direct evidence of MIC involvement. Swab samples, coupon samples, and biofilm scraped from internal surfaces can be analyzed by conventional culture methods or, more reliably, by molecular techniques including qPCR and next-generation sequencing. These molecular approaches can identify specific organisms and quantify their relative abundance without requiring laboratory culture, which has historically underrepresented slow-growing or obligate anaerobe populations. Water samples provide information about planktonic populations, however, they are poor indicators of biofilm activity; surface samples are always preferable for MIC investigation.

9.3 Corrosion Monitoring Programs

Ongoing corrosion monitoring programs in MIC-susceptible infrastructure typically combine periodic inspection with continuous or semi-continuous measurement of parameters indicative of corrosion activity. Corrosion coupons, small metal samples installed in bypass flow loops or directly in the process stream (see Figure 11), provide a direct measure of weight loss over the exposure period. They can be submitted for microbiological and metallurgical analysis at the end of each exposure interval. Electrochemical noise monitoring and linear polarization resistance (LPR) probes provide real-time corrosion rate data without requiring coupon removal, though interpreting these signals in biologically active environments requires some care because biofilm impedance can interfere with standard electrochemical measurements.




Figure 11: Close-up of the corroded coupon covered with biofilm and corrosion products (a), and surface of the cleaned coupon (b). Credit: Chatterjee et al., 2021

In water distribution systems, residual disinfectant monitoring at representative points throughout the network serves as a proxy for biofilm control effectiveness. Where residuals decay faster than the hydraulic model predicts, elevated biofilm oxygen demand is a plausible explanation, and targeted inspection of those segments may reveal active MIC. Turbidity spikes and water color complaints from distribution system users are additional indicators of biological activity that warrant investigation.

9.4 Microbiological Sampling Protocols for MIC Investigation

Effective microbiological sampling in a MIC investigation requires more care than simply collecting a water sample and sending it to a laboratory. The organisms most relevant to MIC, including obligate anaerobes such as SRB, are sensitive to oxygen exposure and can lose viability within minutes of being removed from an anaerobic environment. Water samples collected in standard laboratory bottles and shipped without special precautions may significantly undercount anaerobic populations, leading to a false conclusion that SRB are absent or insignificant.

Best practice for SRB sampling involves collecting samples directly into anaerobic culture media or oxygen-scavenging transport media using pre-reduced sample vials or syringes purged with nitrogen gas. For surface sampling, swabs or scrapers used to collect biofilm from a pipe interior should be immediately transferred to pre-reduced transport medium. For pipeline systems, samples collected immediately downstream of a PIG run, which displaces and mixes internal biofilm and deposits, can provide more representative biological information than samples from flowing sections where biofilm organisms are not well represented in the bulk water.

Molecular methods have largely supplanted culture-based methods in research, and they are increasingly being adopted in engineering practice. Quantitative PCR targeting the *dsrB* gene, which encodes a key enzyme in the sulfate reduction pathway, provides a direct measure of SRB genetic material in the sample regardless of whether the organisms are viable under culture conditions. This method can detect SRB at concentrations of a few hundred cells per milliliter of water or per square centimeter of surface area, well below the sensitivity of most culture methods. Next-generation sequencing of the 16S ribosomal RNA gene allows the complete microbial community to be characterized from a single sample, identifying all organism groups present and their relative abundance. These data support a more complete picture of MIC risk than SRB-focused testing alone, because the presence of SOB, IOB, or APB alongside SRB suggests an active sulfur cycle capable of producing both sulfide and acid attack simultaneously.

CHAPTER 10

Protective Systems, Chemical Treatment, and Operational Mitigation

10.1 Protective Coatings and Linings

Coatings and internal linings are the first line of defense against MIC in most infrastructure systems, providing a physical barrier between the metal surface and the biological environment. Their effectiveness in MIC control depends on barrier integrity. A coating with a single holiday, an adhesion failure zone, or a mechanical defect provides an attachment site for biofilm that is then shielded from biocide treatment by the surrounding intact coating. The metal beneath that holiday is exposed to the concentrated metabolic products of the biofilm, without any of the protective treatment chemistry that might otherwise suppress microbial activity. This is why coating specification and quality assurance during application are so important in MIC-susceptible environments, arguably more so than in environments where corrosion is primarily uniform.

Fusion-bonded epoxy (FBE) coatings are widely specified for internal protection of water and gas distribution pipelines. This is because they provide a continuous, chemically resistant barrier with good adhesion to steel surfaces and minimal porosity when applied under proper conditions. Cement mortar lining is the traditional choice for ductile iron water main, providing a passive alkaline environment at the pipe surface that suppresses many corrosion mechanisms including MIC. The alkaline pH maintained by the cement tends to inhibit SRB activity, though in severely aggressive environments, the buffering capacity of the lining can be exhausted over time, particularly in soft, low-alkalinity water that provides little additional buffering.

Antimicrobial coatings represent a more recent approach that incorporates biocidal compounds, typically silver ions, copper compounds, or quaternary ammonium biocides, directly into the coating matrix. These compounds are released gradually at the coating surface, maintaining a localized biocidal effect that suppresses biofilm attachment. The approach is well established in marine antifouling coatings and is being evaluated for water infrastructure and industrial applications. The challenge is ensuring that the biocide release rate remains effective over the intended service life while staying within regulatory limits for the water chemistry parameters the coating is intended to protect.

10.2 Cathodic Protection in MIC Environments

Cathodic protection (CP) reduces corrosion by supplying electrons to the protected metal surface, raising the metal potential to a range where anodic dissolution is suppressed. For buried pipelines and marine structures, CP is a well-established and effective tool, but its interaction with MIC environments introduces complications that engineers need to understand.

SRB in anaerobic soils can continue to generate hydrogen sulfide even when the adjacent metal is cathodically protected. This is because the biological sulfur reduction process is driven by bacterial metabolism rather than by the metal potential. If the CP current is sufficient to maintain protection at the metal surface beneath a developing biofilm, protection is preserved. If the biofilm or a coating defect allows the SRB to establish directly at the metal surface, the local chemistry may vary sufficiently from the bulk soil conditions that conventional CP design criteria do not ensure protection.

Overprotection, maintaining a cathodic potential more negative than necessary, can also exacerbate hydrogen-related damage mechanisms in high-strength steels. They can also produce alkaline conditions at the metal surface that potentially influence microbial community composition. Modern CP design for environments with known SRB activity accounts for these considerations and may specify more frequent potential surveys, targeted biofilm sampling at representative test points, and more frequent coupon evaluation to confirm that the combined protection system is achieving its intended performance.

10.3 Biocides and Chemical Treatment

Biocide treatment programs are widely used in cooling water systems, oil and gas production systems, and water distribution networks to control microbial populations and suppress biofilm growth. Biocides fall into two principal categories:

- Oxidizing biocides, which include chlorine, chloramine, chlorine dioxide, hydrogen peroxide, and ozone.
- Non-oxidizing biocides, which include quaternary ammonium compounds, glutaraldehyde, isothiazolinone compounds, and tributyltin compounds (where permitted).

The two categories are typically used in combination, with the oxidizing biocide providing rapid broad-spectrum kill and the non-oxidizing biocide penetrating

biofilm structure to address the more protected populations within the EPS matrix.

The central challenge in biocide program design for MIC control is that mature biofilms are substantially more resistant to biocides than planktonic cultures of the same organisms. The EPS matrix retards biocide diffusion into the biofilm interior, the high local density of organisms creates high biocide demand, and organisms in the deepest biofilm layers may exist in metabolically dormant states that are intrinsically resistant to oxidative attack. A biocide dose that achieves 99% kill of planktonic SRB in a laboratory test, may achieve only 50% to 70% kill within a mature pipeline biofilm, leaving a substantial surviving population capable of recolonizing the system after treatment ends. This reality explains why shock treatment with high biocide doses, followed by regular maintenance doses, is generally more effective than continuous low-level dosing for biofilm-established systems.

Dispersants and biofilm-penetrating agents are often used in conjunction with biocides to improve penetration and remove dislodged biofilm fragments before they settle and re-establish in a downstream location. Physical cleaning methods, including high-velocity flushing, pigging, and foam cleaning, are particularly effective at removing bulk biofilm deposits in pipeline systems and should typically precede or accompany chemical treatment programs rather than being used as alternatives to them.

10.4 Operational Mitigation Strategies

Operational controls are often the most cost-effective MIC mitigation measures available, and they should be considered during system design rather than retrofitted after problems develop. Maintaining minimum flow velocities above the threshold for biofilm establishment, typically around 0.3 to 0.6 m/s (1 to 2 ft/s) in water systems, prevents the stagnation conditions that allow organisms to attach and grow. Designing systems to eliminate or minimize dead legs removes the most vulnerable locations from the start. Where dead legs are unavoidable, regular flushing schedules and inspection protocols maintain awareness of their condition.

Temperature management is relevant in HVAC and cooling water applications. Maintaining cold water return temperatures below the growth optimum for *Legionella* (below 20°C or 68°F), and hot water system temperatures above the inactivation threshold (above 60°C or 140°F), suppresses the organisms of greatest public health concern while also reducing MIC risk from mesophilic SRB

populations. In industrial systems where temperature control is not feasible, increased inspection frequency and more aggressive biocide programs substitute for environmental control.

The importance of maintaining accurate operational records cannot be overstated. MIC failures frequently occur in systems where the flow history, treatment records, and inspection results are incomplete or poorly documented, making it impossible to reconstruct the conditions that allowed biological deterioration to progress to failure. Asset integrity management programs that maintain longitudinal data on corrosion monitoring results, water chemistry, biocide dosing, and inspection findings provide the foundation for recognizing deterioration trends before they reach the failure threshold.

10.5 Integrated Mitigation Programs and Program Evaluation

Effective MIC control in most infrastructure systems requires an integrated program that combines multiple mitigation strategies rather than relying on any single approach. For example, chemical treatment suppresses planktonic and some biofilm populations but does not address the structural conditions that allow biofilm to establish. Coatings provide a barrier but degrade over time, and a coating with holidays provides no protection at these points without supplementary cathodic protection or biocide treatment. Operational controls reduce stagnation, and nutrient accumulation but may be constrained by system demand requirements. The engineering task is to design a combination of measures that collectively provides adequate protection throughout the intended service life of the asset, accounting for the anticipated degradation of each individual measure over time.

Program evaluation is a critical but often neglected component of MIC management. A biocide dosing program, a coating specification, or a cathodic protection system that was adequate when installed may become insufficient as the infrastructure ages, as the operating environment changes, or as the microbial community adapts. Regular evaluation of program effectiveness, through corrosion coupon weight loss data, inspection findings, and periodic microbiological testing, allows engineers to detect declining effectiveness before it leads to accelerated corrosion. Where the monitoring data indicate that the program is no longer achieving its intended performance, modification or supplementation of the mitigation approach is warranted before damage accumulates.

Documentation of mitigation program activities, inspection findings, and corrosion monitoring data over the full asset lifecycle creates a longitudinal record that is invaluable for engineering analysis and for demonstrating regulatory compliance. Many MIC failures that could have been prevented involved systems where adequate data existed to identify the developing problem, but they were not reviewed systematically or were not connected to a decision-making process that could initiate corrective action in time. Building the organizational processes for regular data review and action into the asset management program is as important as the technical content of the mitigation measures themselves.

CHAPTER 11

Lifecycle Engineering, Risk Assessment, and Emerging Technologies

11.1 Lifecycle Engineering and MIC Risk

MIC is fundamentally a lifecycle problem. The deterioration it causes typically takes months to years to develop from initial biofilm establishment to detectable wall loss. By the time failure occurs, the biological and environmental conditions that created the problem may have changed substantially. Engineers who manage infrastructure through its full operational life, rather than at design and installation only, are in the best position to detect MIC trends early and intervene before the damage crosses the threshold of structural significance.

Lifecycle engineering for MIC-susceptible infrastructure involves three core elements:

- Risk assessment to identify which assets and asset segments face the greatest MIC exposure.
- Baseline and monitoring programs to track corrosion development over time.
- Consequence analysis to prioritize inspection and maintenance resources toward the failures that would be most damaging in terms of safety, environmental impact, and service disruption.

This is essentially the framework of risk-based inspection (RBI), which has been formalized in API Recommended Practice 580 and related guidance documents for the oil and gas sector and is increasingly being applied in water and wastewater utility management (Javaherdashti, 2008).

A MIC risk assessment begins with characterizing the likelihood of biological colonization in each asset segment. Key factors include operating temperature, flow velocity, water chemistry, the presence of nutrients and sulfate, and the history of microbiological detection in the system. Assets with high likelihood scores, combined with high consequence scores based on their criticality and failure impact, receive the most intensive monitoring and the most frequent inspection. Assets with low likelihood and low consequence may be adequately managed by periodic inspection without dedicated MIC monitoring. The value of

this risk stratification is that it allows limited inspection and maintenance budgets to be directed where the benefit is greatest.

11.2 Predictive Maintenance and Digital Approaches

The transition from reactive maintenance, repairing failures after they occur, toward predictive maintenance, intervening based on detected deterioration trends before failure, represents one of the most significant shifts in infrastructure management practice over the past two decades. For MIC specifically, predictive approaches are attractive because the biological and electrochemical processes involved give observable signals, in the form of corrosion rate measurements, biofilm detection, and water chemistry trends, that can be tracked over time and projected into future condition estimates.

Corrosion monitoring data, when accumulated over multiple inspection cycles, allows statistical modeling of wall loss rates at specific locations. Where wall loss is accelerating relative to the baseline rate, early investigation is warranted. Where it is decelerating, perhaps because treatment or operational changes have been effective, the monitoring interval can be extended. This kind of data-driven decision making is qualitatively different from the time-based inspection schedules that still dominate much of the infrastructure sector, and it generally provides better safety assurance at lower total cost.

Digital twin models, computational representations of physical infrastructure systems that are updated with real-time sensor data, are beginning to be applied in MIC management contexts. A pipeline digital twin that incorporates flow conditions, temperature profiles, water chemistry, and historical inspection results can be used to predict where MIC is most likely to be active, and what the wall loss rate is likely to be over the next inspection interval. This allows inspection resources to be targeted at the highest-risk locations rather than distributed uniformly across the asset. Several large pipeline operators in North America and Europe have begun deploying early versions of this approach, and the technology is advancing rapidly.

11.3 Emerging Technologies in MIC Detection and Control

Molecular biology has transformed the capacity to characterize microbial populations in engineering environments. Next-generation sequencing (NGS) techniques can profile the entire microbial community in a biofilm or water sample from a few milliliters of collected material, providing a detailed inventory of which organisms are present and in what relative abundance. This replaces the

decades-old culture method, which required that organisms survive laboratory conditions in order to be counted, with a method that detects genetic material directly. In an MIC investigation context, NGS can identify the presence of SRB, SOB, and other corrosion-relevant organisms even when their populations are sparse or dominated by non-culturable strains. The technology is becoming more accessible as the cost of sequencing continues to fall, and it is beginning to be incorporated into routine monitoring programs for high-value or high-risk infrastructure systems.

Electrochemical noise monitoring and fiber optic corrosion sensors are extending continuous real-time corrosion monitoring capability to locations that were previously only accessible by periodic inspection. Electrochemical noise sensors detect the current and voltage fluctuations associated with active corrosion events, including the episodic pitting events characteristic of MIC. Fiber optic distributed sensing systems can measure temperature and strain along the entire length of a pipeline from a single measurement point, identifying temperature anomalies that may indicate microbial hot spots or the early stages of a leak. As sensor costs decrease and wireless data transmission infrastructure becomes more widespread, the density of real-time monitoring on critical infrastructure is increasing substantially.

Biologically inspired antifouling technologies represent a longer-term research direction with potential implications for MIC control. Natural marine organisms, including certain species of sea squirts, bryozoans, and corals, maintain biofilm-free surfaces in biologically rich marine environments through surface microstructure and the local release of natural antifouling compounds. Researchers are developing synthetic analogues to these natural surface properties, such as textured polymer coatings that mechanically discourage cell attachment, and coating matrices that release natural antimicrobial compounds at controlled rates without the environmental persistence concerns associated with traditional biocides. Several of these approaches have progressed from laboratory demonstration to field trials in marine and industrial applications.

Table 4 below includes some of the emerging MIC monitoring and control technologies, their engineering applications, and current deployment status.

Table 4: Emerging MIC Monitoring and Control Technologies.

Technology	Application	Current Status
Next-generation DNA sequencing (NGS)	Microbial community profiling from biofilm and water samples	Commercially available; increasingly used in failure investigation and monitoring
Electrochemical noise monitoring	Real-time detection of pitting events in pipelines and vessels	Field-deployed in high-value industrial applications; interpretation protocols developing
Digital twin modeling	Predictive corrosion modeling combining operational data with inspection history	Deployed by leading pipeline operators; widespread adoption expected within 5 years
Inline inspection robotics	High-resolution inspection of pipelines and tanks in difficult-access environments	Commercially deployed in pipeline and tank inspection; capabilities expanding rapidly
Antimicrobial coating systems	Prevention of biofilm attachment in water and marine infrastructure	Established in marine antifouling; field trials in water infrastructure ongoing
Distributed fiber optic sensing	Continuous temperature and strain monitoring along pipeline length	Deployed on some high-consequence pipelines; cost barriers limiting broader adoption

11.4 The Engineer's Evolving Role in MIC Management

The broader lesson that MIC engineering teaches is one about the limits of design-phase decision making. Infrastructure placed in service does not enter a static chemical and biological environment; it enters a living one that evolves over months and years in response to operational changes, aging, and external conditions. A pipeline that meets all specifications at commissioning can develop active MIC within a decade if operational conditions shift in ways that were not anticipated during design. Managing this reality requires engineers who maintain engagement with their infrastructure throughout its operational life, not only at design and installation.

The tools available for that ongoing engagement are improving rapidly. Real-time sensors, molecular biology, and predictive modeling are giving engineers unprecedented visibility into what is happening inside buried pipes, submerged structures, and sealed industrial systems. The challenge is translating that visibility into effective intervention decisions, which requires the integrated understanding of corrosion science, microbiology, and infrastructure

engineering that this course has aimed to provide. MIC management is, at its core, a systems engineering problem, and systems-level thinking applied consistently over the asset lifecycle is the most effective response to it.

11.5 Economic Justification for MIC Management Investment

One of the practical challenges in MIC management is making the economic case for proactive investment in monitoring, mitigation, and inspection programs when the alternative, reactive maintenance, has a lower immediate cost even if a higher lifecycle cost. Infrastructure owners with constrained capital budgets often defer proactive corrosion management in favor of more immediately visible expenditures, accepting the risk of more costly emergency repairs and asset replacement in future budget cycles. Demonstrating the economic return on MIC management investment requires quantifying both the cost of failures that are prevented and the cost of the management program itself.

Failure cost analysis for MIC events typically includes direct repair or replacement costs, indirect costs from service interruption or production downtime, environmental remediation if the failure involves a release, regulatory penalty risk, and the cost of emergency response. For high-consequence infrastructure such as large-diameter transmission mains, major pipeline systems, or industrial processing equipment with significant downstream dependencies, even a single prevented failure, can exceed the cost of a multi-year monitoring program. The NACE International cost study (Koch et al., 2002) estimated that optimally applying currently available corrosion control technologies could reduce the annual cost of corrosion in the United States by 25% to 30%, implying a potential saving of \$70 billion or more annually. While not all of this saving is attributable specifically to MIC, it reflects the broader principle that proactive corrosion management is economically advantageous even when the initial investment appears expensive.

The risk-based inspection framework provides the economic structure for allocating MIC management resources efficiently. By concentrating inspection and monitoring resources on high-likelihood, high-consequence asset segments, an operator can achieve meaningful risk reduction without the cost of monitoring every segment of the infrastructure network at the same frequency. Segments assessed as low risk can be managed with longer inspection intervals and simpler monitoring approaches, freeing budget for more intensive attention to the segments where failure would be most costly. This kind of explicit risk-prioritized resource allocation is now standard practice in the oil and gas sector under API

RP 580, and is being adopted increasingly in the water utility and industrial sectors as well.

References

- American Water Works Association. (2012). Internal corrosion of water distribution systems (2nd ed.). AWWA.
- Borenstein, S. W. (1994). Microbiologically influenced corrosion handbook. Industrial Press.
- Characklis, W. G., & Marshall, K. C. (Eds.). (1990). Biofilms. John Wiley & Sons.
- Flemming, H.-C. (2002). Biofouling in water systems: Cases, causes and countermeasures. *Applied Microbiology and Biotechnology*, 59(6), 629–640.
- Fontana, M. G. (1986). Corrosion engineering (3rd ed.). McGraw-Hill.
- Hamilton, W. A. (2003). Microbially influenced corrosion as a model system for the study of metal-microbe interactions: A unifying electron transfer hypothesis. *Biofouling*, 19(1), 65–76.
- Hindieh, P., Yaghi, J., Assaf, J. C., Chokr, A., Atoui, A., Tzenios, N., Louka, N., & Khoury, A. E. (2025). Emerging Multimodal Strategies for Bacterial Biofilm Eradication: A Comprehensive Review. *Microorganisms*, 13(12), 2796.
- Javaherdashti, R. (2008). Microbiologically influenced corrosion: An engineering insight. Springer.
- John, B., & Mubarak, S. (2022). Pipe inspection robots: a review. *IOP Conference Series: Materials Science and Engineering*. 1272(1):012016.
- Jones, D. A. (1996). Principles and prevention of corrosion (2nd ed.). Prentice Hall.
- Kiani Khouzani, M., Bahrami, A., Hosseini-Abari, A., Khandouzi, M., & Taheri, P. (2019). Microbiologically Influenced Corrosion of a Pipeline in a Petrochemical Plant. *Metals*, 9(4), 459.
- Koch, G. H., Brongers, M. P. H., Thompson, N. G., Virmani, Y. P., Payer, J. H. (2001). Corrosion cost and preventive strategies in the United States.
- Little, B. J., & Lee, J. S. (2009). Microbiologically influenced corrosion. *International Materials Reviews*, 59 (7).
- Mi, Z., Zhang, X., Chen, C. (2015). Iron release in drinking water distribution systems by feeding desalinated seawater: characteristics and control. *Desalination and Water Treatment*. 57. 1-8.
- NACE International. (2006). Mitigation of microbiologically influenced corrosion (NACE SP0106-2006). NACE International.

- Rao, P., Mulky, L. Microbially Influenced Corrosion and its Control Measures: A Critical Review. *J Bio Tribo Corros*, 9, 57 (2023).
- Revie, R. W., & Uhlig, H. H. (2008). *Uhlig's corrosion handbook* (3rd ed.). John Wiley & Sons.
- Tripathi, A., Thakur, P., Saxena, P., Rauniyar, S., Gopalakrishnan, V., Singh, R.N., Venkataramana, G., Gnimpieba, E.Z., & Jasthi, B., Sani, R. (2021). Gene Sets and Mechanisms of Sulfate-Reducing Bacteria Biofilm Formation and Quorum Sensing With Impact on Corrosion. *Frontiers in Microbiology*. 12.
- U.S. Department of Transportation, Pipeline and Hazardous Materials Safety Administration. (2007). Amendment No. 3 to corrective action order: BP Exploration Alaska, Inc. (CPF No. 5-2006-5015H). U.S. DOT.
- U.S. Environmental Protection Agency. (2002). Wastewater technology fact sheet: Odor control for collection systems (EPA 832-F-99-075). U.S. EPA.
- Videla, H. A. (1996). *Manual of biocorrosion*. CRC Press.
- Videla, H. A., & Herrera, L. K. (2005). Microbiologically influenced corrosion: Looking to the future. *International Microbiology*, 8(3), 169–180.
- Wani, T.I., Rallapalli, S., Singhal, A., Robert, D., Kodikara, J., Pramanik, B.K., Arya, S.B. (2025). Compounded fuzzy entropy-based derivation of uncertain critical factors causing corrosion in buried concrete sewer pipeline. *npj Clean Water*. 8. 10

Disclaimer

This course was prepared by Cadistics Courseware.

Copyright © Cadistics, LLC 2026. All rights reserved.

Educational Use Only

The content of this course is provided for educational purposes only. While every effort has been made to ensure the accuracy and reliability of the information presented, the author or publisher makes no guarantees regarding the completeness or applicability of the information to specific professional practices. Users are advised to consult additional resources and exercise professional judgment when applying the knowledge contained in this course.

Use of AI Generated Content

The continuing education (CE) courses offered on this platform are developed using advanced artificial intelligence (AI) methodologies to generate high-quality, text-based instructional content.

These courses are primarily designed to provide in-depth knowledge on engineering and technical subjects with minimal or no imagery, focusing on comprehensive textual explanations to convey concepts effectively.

While every effort is made to ensure accuracy, clarity, and compliance with professional standards, the nature of AI-assisted content generation means that occasional errors or inconsistencies may occur. Users are encouraged to critically evaluate the material and verify key technical details as needed. Additionally, these courses do not include interactive elements or extensive visual aids such as diagrams, charts, or illustrations unless explicitly stated.

By enrolling in and using these courses, participants acknowledge and accept that the content is primarily text-based and generated through AI-assisted processes. The course provider assumes no liability for any inaccuracies or omissions and advises professionals to apply their own judgment and expertise when utilizing course materials in practical applications.